

	3/2" Reducer				
	Transitions vent system to a smaller diameter.				
	Nominal Diameter	Part	Overall Length A	Effective Length B	Max O.D. C
	3"/2" (80/60)	ISRD0302	6.0 (153)	3.5 (89)	3.2 (80)

	Reducers				
	Transitions vent system to a smaller diameter.				
	Nominal Diameter	Part	Overall Length A	Effective Length B	Max O.D. C
	4"/3" (110/80)	ISRD0403	6.0 (153)	3.5 (89)	4.3 (110)
	6"/4" (160/110)	ISRD0604	6.5 (166)	4.0 (102)	6.3 (160)
	6"/4" (150/110)	ISRD15004	8.8 (223)	6.5 (165)	5.9 (150)

Test Ports

	Test Ports				
	Installed immediately above the appliance, the test port allows plumbing and heating professionals to sample flue gases and ensure the appliance is operating at optimum efficiency.				
	Nominal Diameter	Part	Overall Length A	Effective Length B	Max O.D. C
	2" (60)	ISTP02	7.0 (170)	4.3 (110)	3.0 (76)
	3" (80)	ISTP03	7.0 (170)	4.5 (115)	3.8 (97)
	4" (110)	ISTP04	12.4 (314)	9.8 (250)	5.1 (129)